

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08001

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.064	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08002

Description: 8G EXT LEAD

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.04	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	238	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08003

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.094	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08004

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.052	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08005

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.12	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08006

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.056	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08007

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.14	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08008

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.092	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08009

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.1	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08010

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.06	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08011

Description: SHOWTEC MICRO SPOT

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.046	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	237	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08012

Description: CHAOVET MICRO SPOT

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.048	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	237	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08013

Description: SHOWTEC MICRO SPOT

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.04	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	242	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08014

Description: CHAOVET MICRO SPOT

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.086	ohm	Pass
Insulation Resistance	155	MOhm	Pass
Live Voltage	242	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08015

Description: AC POWER ADAPTER

Test	Result	Unit	Status
Visual			Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	241	V	Information
Neutral Voltage	8	V	Information
Touch Current	< 0.07	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08016

Description: NUMARK WIRELESS RECIVER

Test	Result	Unit	Status
Visual			Pass
Insulation Resistance	> 199	MOhm	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08017

Description: 4G EXT LEAD

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.034	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	242	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	0.2	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08018

Description: AC POWER ADAPTER

Test	Result	Unit	Status
Visual			Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	243	V	Information
Neutral Voltage	8	V	Information
Touch Current	< 0.07	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08019

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.146	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08020

Description: AC POWER ADAPTER

Test	Result	Unit	Status
Visual			Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	241	V	Information
Neutral Voltage	8	V	Information
Touch Current	< 0.07	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08021

Description: NUMARK ICDX UNIT

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.04	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08022

Description: IEC POWER LEAD

Test	Result	Unit	Status
Visual			Pass
IEC Lead Continuity	0.068	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08023

Description: AC POWER ADAPTER

Test	Result	Unit	Status
Visual			Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	242	V	Information
Neutral Voltage	8	V	Information
Touch Current	< 0.07	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08024

Description: NUMARK ICDX UNIT

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.07	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08025

Description: NUMARK DM MIXING UNIT

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.066	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08026

Description: GEMINI GX450 SPEAKER

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.034	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	242	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08027

Description: GEMINI GX450 SPEAKER

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.046	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	242	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08028

Description: NUMARK DM MIXING UNIT

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.046	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08029

Description: QSC HPR152F SPEAKER

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.038	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	241	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08030

Description: QSC HPR152F SPEAKER

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.042	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	244	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08031

Description: 4G EXT LEAD

Test	Result	Unit	Status
Visual			Pass
Earth Continuity	0.05	ohm	Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	241	V	Information
Neutral Voltage	8	V	Information
PE Conductor Current	< 0.15	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08032

Description: LT AC POWER ADAPTER

Test	Result	Unit	Status
Visual			Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	243	V	Information
Neutral Voltage	8	V	Information
Touch Current	< 0.07	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred

Test Certificate



The Southern Pat Company Ltd

Portable Appliance Testing Engineers

Tests Conducted By: The Southern Pat Company Ltd, Oaklands House, 40 Highfield Drive, Epsom, Surrey, KT19 OAS

On Behalf Of: Great Muzik, 7 Swans Meadow, Bookham, Surrey, KT23 4JX

Site: Bookham

Location: KT23 4JX

Asset: 08033

Description: LT AC POWER ADAPTER

Test	Result	Unit	Status
Visual			Pass
Insulation Resistance	> 199	MOhm	Pass
Live Voltage	239	V	Information
Neutral Voltage	8	V	Information
Touch Current	< 0.07	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 23/07/2008

Test Instrument: PrimeTest 300 W02-0416

Tested By: SPCL SA003

Test Engineer: S.T Aldred